

Utility Conflict Report

OWNER	Utility	SAWS	Corridor	WW WHITE	SITE PHOTOS	
	Contact	NINA BITTLE	ID	251		
GENERAL INFO	Utility	WATER				
	Size and Material	STANDARD WATER VALVE, CAST IRON				
	Utility Conflict Description	WATER VALVE WITHIN PROPOSED SIDEWALK				
	Longitudinal or Crossing	CROSSING				
	Placement Relative to ROW	INSIDE				
LOCATION	Sheet No.	197				
	Station Origin					
	Start Station	327+29.92	End Station			
	Start Offset	31.40	End Offset			
	Latitude	+29.435670	Longitude	-98.405376648		
	SUE	Level of Investigation Req'd	NONE			
Test Hole No		N/A				
Test Hole Depth		N/A				
RESOLUTION	Recommended Action	MINIMIZE - PROTECT IN PLACE				
	Estimated Resolution Date					
	Resolution Status	UTILITY CONFLICT RESOLVED				
	Comment	ADJUST WATER VALVE LID TO PROPOSED GRADE DURING CONSTRUCTION (<1" VERTICAL CHANGE ANTICIPATED)				
Date Collected		11/27/2017 9:47:57 AM		Date Modified 8/17/2018 2:20:30 PM		

