

Utility Conflict Report

OWNER	Utility	SAWS	Corridor	WW WHITE	SITE PHOTOS
	Contact	NINA BITTLE	ID	252	
GENERAL INFO	Utility	WATER			
	Size and Material	STANDARD WATER VALVE, CAST IRON			
	Utility Conflict Description	WATER VALVE WITHIN PROPOSED SIDEWALK			
	Longitudinal or Crossing	CROSSING			
	Placement Relative to ROW	INSIDE			
LOCATION	Sheet No.	197			
	Station Origin				
	Start Station	327+28.81	End Station		
	Start Offset	30.80	End Offset		
	Latitude	+29.43566755	Longitude	-98.405378710	
SUE	Level of Investigation Req'd	NONE			
	Test Hole No	N/A			
	Test Hole Depth	N/A			
RESOLUTION	Recommended Action	MINIMIZE - PROTECT IN PLACE			
	Estimated Resolution Date				
	Resolution Status	UTILITY CONFLICT RESOLVED			
	Comment	ADJUST WATER VALVE LID TO PROPOSED GRADE DURING CONSTRUCTION (1-2" VERTICAL RISE ANTICIPATED)			
Date Collected		11/27/2017 10:24:34 AM	Date Modified		8/17/2018 2:20:32 PM

