




Utility Conflict Report

OWNER	Utility	SAWS	Corridor	NOGALITOS	SITE PHOTOS
	Contact	ANN PECHE	ID	3052	
GENERAL INFO	Utility	WATER			
	Size and Material	STANDARD WATER METER, STEEL			
	Accessible Route	ASSET IS INSIDE ACCESSIBLE ROUTE			
	Longitudinal or Crossing	CROSSING			
	Placement Relative to ROW	INSIDE ROW			
LOCATION	Sheet No.	128			
	Station	138+34.41			
	Offset	-27.25			
	Latitude	+29.394521			
	Longitude	-98.51697			
SUE	Level of Investigation Req'd	NONE			
	Test Hole No	N/A			
	Test Hole Depth	N/A			
RESOLUTION	Recommended Action	MINIMIZE - PROTECT IN PLACE			
	Estimated Resolution Date				
	Resolution Status	UTILITY OWNER INFORMED OF UTILITY			
	Comment	Top of meter to surface = 3" Oval rubber lid thickness = 2" Meter to back of curb = 3'-4" Sidewalk width = 5'-5" Lower underlying asset, not enough vertical clearance inside meter box to lower 4-5" needed			
Date Collected		7/11/2018 8:44:36 AM	Date Modified		10/12/2018 3:14:06 PM

TBPE Firm Registration #470 | TBPLS Firm Registration #10028800