

CONFERENCE MEMO

SH 46 to SH 123

PROJECT:

~~Cordova Rd between SH 46
and SH 123~~
Seguin, TX

DATE:

August 8, 2023

CONFERENCE LOCATION:

Virtual – Microsoft Teams
Meeting

CONFERENCE DATE:

August 8, 2023

PURPOSE OF MEETING:

GVEC Utility Meeting

ATTENDEES:

Deepa Elter – Pape-Dawson
Steven Tate - Pape-Dawson
David Wilder - Pape-Dawson
Travis Engler - GVEC
Matthew Allen - GVEC

FROM:

Deepa Elter

PROJECT NO.:

12775-00

, P.E., CFM

cc:

Attendees, File

DISCUSSION:

Below is an outline of the discussion and direction for the project listed above. **Action items and/or question responses are shown in the bold and italic format.**

- Scope
- Huber Road Project
- Specific Conflicts

add Cordova scope in
indendent bullet point

Aquire *variable width*
ROW, 120' minimum

GVEC – Specific Conflicts

- Crossing ← "- total X crossings"

Conflict ID	Sheet No.	Type	Offset	Station Range	Side of Road	Recommendation
46	7	OHE	Cordova Rd	131+48-131+60	North and South	Check sag height
55	8	OHE	Cordova Rd	147+50-147+93	North and South	Relocate within 3' of ROW and check sag height
72	9	OHE	Cordova Rd	157+43-157+74	North and South	Check sag height
354	10	OHE	Cordova Rd	160+79-160+86	North and South	Relocate within 3' of ROW and check sag height
91	10	OHE	Cordova Rd	163+14-163+52	North and South	Relocate within 3' of ROW and check sag height
109	11	OHE	Cordova Rd	165+48-165+50	North and South	Relocate within 3' of ROW and check sag height
154	14	OHE	Cordova Rd	203+81-204+42	North and South	Relocate within 3' of ROW and check sag height
164	14-15	OHE	Cordova Rd	205+99-206+00	North and South	Check sag height
181	16	OHE	Cordova Rd	216+03-216+10	North and South	Relocate within 3' of ROW and check sag height
193	17	OHE	Cordova Rd	230+36-230+41	North and South	Relocate within 3' of ROW and check sag height
198	17	OHE	Cordova Rd	233+76-233+84	North and South	Relocate within 3' of ROW and check sag height
241	19	OHE	Cordova Rd	252+98-253+03	North and South	Relocate within 3' of ROW and check sag height
244	19	OHE	Cordova Rd	254+68-254+98	North and South	Relocate within 3' of ROW and check sag height

design for proposed roadway profile min clearance and perpendicular cross

- Longitudinal

Conflict ID	Sheet No.	Type	Offset	Station Range	Side of Road	Recommendation
11	2-24	OHE	Cordova Rd	172+76-280+09	North	Relocate within 3' of ROW
22	6	OHE	Cordova Rd	126+01-126+02	North	Relocate within 3' of ROW
368	7	OHE	Cordova Rd	135+06-135+10	North	Relocate within 3' of ROW and check sag height
40	7	OHE	Cordova Rd	138+33	North	Relocate within 3' of ROW and check sag height
59	9	OHE	Cordova Rd	152+76-153+11	North	Relocate within 3' of ROW and check sag height
77	9	UGE	Cordova Rd	157+66-159+97	North	Relocate within 3' of ROW
67	9-24	OHE	Cordova Rd	154+98+280+15	North	Relocate within 3' of ROW
118	12	OHE	Cordova Rd	176+89-177+00	North	Relocate within 3' of ROW
125	12	OHE	Cordova Rd	183+46	North	Relocate within 3' of ROW
126	12	OHE	Cordova Rd	184+97-184+98	North	Relocate within 3' of ROW
151	14	OHE	Cordova Rd	202+72-202+79	North	Relocate within 3' of ROW
288	24	OHE	Cordova Rd	280+15-281+63	North	Relocate within 3' of ROW

- Underground Electric

Conflict ID	Sheet No.	Type	Offset	Station Range	Side of Road	Recommendation
77	9	UGE	Cordova Rd	157+66-159+97	North	Relocate within 3' of ROW
280	22-26	UGE	Cordova Rd	273+57-294+16	North and South	Relocate within 3' of ROW and adjust to make perpendicular to roadway
306	24-26	UGE	Cordova Rd	282+32-293+89	North	Relocate within 3' of ROW
330	26	UGE	Cordova Rd	293+06-293+17	North and South	Adjust to make perpendicular to roadway

review depth and easement information

- The above conflicts reflect the pertinent conflicts, but refer to the UCM for the full list of conflicts
- Questions and Open Discussion

END OF MEMO